

Contents

1 NECESSITY OF IMPROVING THE LEAK TIGHTNESS OF REFRIGERATION PRODUCTS AND COLLATION OF THE REQUIREMENTS RELATING TO THE LEAK TIGHTNESS OF REFRIGERATION SYSTEMS AS WELL AS THE RESULTANT NECESSARY DETECTION SENSITIVITIES OF SYSTEMS FOR AUTOMATIC TIGHTNESS CONTROL OF REFRIGERATION SYSTEMS	4
2 DEFINITIONS	7
3 RESEARCH ON RELEVANT LITERATURE	9
4 DESCRIPTION AND EVALUATION OF EXTERNAL LEAKAGE DETECTION SYSTEMS FOR AUTOMATIC LEAKAGE CONTROL AND DETERMINATION OF THE TOTAL LEAKAGE RATES OF REFRIGERATION SYSTEMS	11
4.1 General considerations	11
4.2 Monitoring the rooms of refrigeration systems using sensors	13
4.3 Monitoring selected parts of refrigeration systems by central gas analyzers	16
4.4 Considerations on refrigerant distribution in rooms in the event of leaks	19
4.5 Conclusions on leakage detection with external leakage detection systems	24
5 DESCRIPTION AND EVALUATION OF INTERNAL LEAKAGE DETECTION SYSTEMS FOR AUTOMATIC LEAKAGE CONTROL AND DETERMINATION OF THE TOTAL LEAKAGE RATES OF REFRIGERATION SYSTEMS	26
5.1 Preliminary remarks on automatic leakage control and determination of the total leakage rates of refrigeration systems with internal leakage detection systems	26
5.2 Description and evaluation of internal leakage detection systems that are used in practical operation or are available for this	28
5.2.1 Early warning unit SICO®-SICH IK 11/12 RSD	28
5.2.2 “Daikin” leakage detection system	31
5.2.3 Monitoring the minimum filling level in the accumulator	36
5.3 Studies and patents on internal leakage detection	37

5.3.1	Monitoring of refrigerant and refrigeration output loss according to Buck (hot-film anemometer in the suction line)	37
5.3.2	Monitoring the refrigerant quantity in the accumulator according to the Linde patent [Gru1], [Gru2]	41
5.3.3	Suction pressure optimization and fault diagnosis in commercial refrigeration systems [Ben]	43
5.3.4	Refrigerant filling quantity indicators for split systems [Mei]	45
5.3.5	Sensitivity of a refrigeration system arrangement to changes in filling quantity [Gra]	46
5.3.6	Fault diagnosis and refrigerant leakage detection in refrigeration systems [Tas]	48
5.3.7	Fault detection for refrigeration systems based on the principle of adapted algorithms (online refrigerant leakage detection) [Nav]	49
5.3.8	Performance investigation of a variable-speed refrigeration system for fault detection and evaluation [Kim]	50
5.3.9	Utilization of thermodynamic influences to detect refrigerant leaks in refrigeration systems [Ros]	53
5.3.10	Bubble detection in the fluid line	56
5.4	Summary and conclusions on the use of internal leakage detection systems in the context of the F-Gas regulation	59
6	SUMMARY OF STATEMENTS ON COMPLIANCE WITH THE REQUIREMENTS OF THE F-GAS REGULATION THROUGH THE USE OF LEAKAGE DETECTION SYSTEMS AND RECOMMENDATIONS FOR FURTHER ACTIVITIES	62
7	REFERENCES	65